

This Addendum is issued to provide for changes in the Work.

Clarifications for questions received via email and general clarifications.

Except as otherwise specified herein, or shown on accompanying drawings, work required by this Addendum shall be in accordance with the Tender Documents dated March 11, 2011.

**1. GENERAL INSTRUCTIONS/CLARIFICATIONS**

- 1.1. A3.0 - Doors are to be constructed of heavy gauge formed and framed stainless-steel. All frame are welded 1-1/2" stainless steel square tubing. Both proprietary and non-proprietary manufacturers are acceptable.
- 1.2. 4/A5.1 – This is a typical elevation, except at BYOB where the rear wall is SS-1 lining to be a minimum thickness of 22 ga. and must be sufficiently thick enough that no oil-canning effect occurs after installation.
- 1.3. Banquette seatings materials to be Vinyls: 32 oz or greater, cotton/polyester back, abrasion 100,000, W-S clean, UFAC-1.
- 1.4. Banquette back of seatings materials to be Fabric: 28 oz or greater, woven, #5 rating at 15,000 cycles (double rubs) or better, stain resistant treated, anti bacterial treated, UFAC-Class I.
- 1.5. Banquette foam to be: High Density foam: Polyurethane, 30 lbs IFD @25% deflection use, high resilience, UFAC-1.

**2. ARCHITECTURAL DRAWINGS**

- 2.1 Drawing 2/A4.0: Deleted, not issued.

**3. ARCHITECTURAL SPECIFICATIONS**

Not Applicable.

**4. STRUCTURAL DRAWINGS AND SPECIFICATIONS**

Not Applicable.

**5. MECHANICAL DRAWINGS AND SPECIFICATIONS**

Not Applicable.

**6. ELECTRICAL DRAWINGS AND SPECIFICATIONS**

- 6.1. All data and TV cabling is supplied and connected by others.

**7. ADDENDUMS**

- 7.1 Add#2: item 1.21 – Dwg 6-10/A5.0 applies to St. James only
- 7.2 Add#2: item 1.22 – A5.3 drawings applies to St. James only.
- 7.3 Add#2: item 1.24 – Existing glass stations to be retained applies to St. James only.
- 7.4 Add #2: item 1.30 – M2 sprinkler installation and deletion information applicable to St. James only.
- 7.5 Add #4 – item 1.3, does not apply to Casa Loma.

**Please note: questions submitted less than 48 hours before tender close may not be answered.**

**END OF ADDENDUM NO. 5**