

This Addendum is issued to provide for changes in the Work.

Clarifications for questions received via email and general clarifications.

Except as otherwise specified herein, or shown on accompanying drawings, work required by this Addendum shall be in accordance with the Tender Documents dated March 11, 2011.

## **1. GENERAL INSTRUCTIONS/CLARIFICATIONS**

- 1.1. 1/A3.0 and 3/A3.0 – There are no curved cabinet doors at the servery counters. Only the countertops are curved. Doors are to be constructed of heavy gauge formed and framed stainless-steel. All frame are welded 1-1/2" stainless steel square tubing. Both proprietary and non-proprietary manufacturers are acceptable.
- 1.2. 3/A5.0 – The fins are spaced approximately 910 apart, centre to centre at the outside curve.
- 1.3. D01 and D02 are new doors (see addendum #4, item 2.3).
- 1.4. A2.2 – White rectangles are Pattern 1 (and the flooring types are shown in sample hatching).
- 1.5. 8/A4.1 – At BYOB rear wall, SS-1 lining to be a minimum thickness of 22 ga. and must be sufficiently thick enough that no oil-canning effect occurs after installation.
- 1.6. Banquette seatings materials to be Vinyls: 32 oz or greater, cotton/polyester back, abrasion 100,000, W-S clean, UFAC-1.
- 1.7. Banquette back of seatings materials to be Fabric: 28 oz or greater, woven, #5 rating at 15,000 cycles (double rubs) or better, stain resistant treated, anti bacterial treated, UFAC-Class I.
- 1.8. Banquette foam to be: High Density foam: Polyurethane, 30 lbs IFD @25% deflection use, high resilience, UFAC-1.

## **2. ARCHITECTURAL DRAWINGS**

- 2.1. 3/A5.0 –Plywood fin assembly: digitally printed self-adhesive vinyl film onto plywood with white p.lam. Pionite sw811 (suede – white). 7mm s.s. plates below. Refer to 8-A5.0

## **3. ARCHITECTURAL SPECIFICATIONS**

Not applicable.

## **4. STRUCTURAL DRAWINGS AND SPECIFICATIONS**

Not Applicable.

## **5. MECHANICAL DRAWINGS AND SPECIFICATIONS**

Not Applicable.

## **6. ELECTRICAL DRAWINGS AND SPECIFICATIONS**

- 6.1. All data and TV cabling is supplied and connected by others.

## **7. ADDENDUMS**

- 7.1 Add#2: item 1.20 – Dwg 6-10/A5.0 applies to St. James.
- 7.2 Add#2: item 1.21 – A5.3 drawings applies to St. James.
- 7.3 Add#2: item 1.23 – Existing glass stations to be retained applies to St. James.
- 7.4 Add #2: item 1.27 – M2 sprinkler installation and deletion information applicable to St. James.

**Please note: questions submitted less than 48 hours before tender close may not be answered.**

**END OF ADDENDUM NO. 5**